

CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

FLO-24-04-03-02

Products: Moduleo Intoo
Nominal thickness: 4,5 mm - Wear layer thickness: 0,55 mm
optional on Xtrafloor Flex Pro underlay 1,8 mm

Client: Unilin BV Division Flooring
Ooigemstraat 3, 8710 Wielsbeke, Belgium

Order: Determination and classification of selected properties
according to EN 14041:2004+AC:2005+AC:2006 (CE-labelling)

Test Report: 2723614, 2723133, 2722570_A1, RL 2023/966-1, RL 2023/966-2, No. 2024/012-2

Test Results:

Property	Results	Declaration according to EN 14041:2004+AC:2005 +AC:2006
Reaction to fire performance according to EN ISO 9239-1:2010 and EN ISO 11925-2:2020, Classification according to EN 13501-1:2018 - Critical heat flux - Smoke production - extent of flame \leq 150 mm	8,2 kW / m ² 345,5 % x min fulfilled	Reaction to fire class B _{fl} -s1*
Slip resistance according to EN 13893:2002-11	$\mu = 0,50$	DS
Formaldehyde emission according to EN 717-1:2004-10	< LOD (144 h)	E1
Content of PCP according to CEN/TR 14823:2004	< LOQ	PCP < 5 ppm
Thermal resistance according to EN 12667:2001-01	0,0134 (m ² K)/W	0,01 (m ² K)/W
Electrostatic behaviour according to EN 1815:2016-09	BV = 0,5 kV	Antistatic floor covering

* Valid on wooden or mineral subfloor in end use application, using adhesive or not.

LOD = Limit of Detection LOQ = Limit of Quantitation BV = Body voltage

Dresden, 03/04/2024

P.P. R. Diehl
Head of laboratory



[Signature]
Engineer in charge